



MEMORANDUM

Our Ref: JA

Application Ref: MO00397

Date: 7th May 2025

CASE 8

From: K. Donoghue
Team Manager, Licensing, Planning & Building Standards.

To: G. McNaught
Legal Manager (Licensing), Corporate Services.

Subject: Consultation: Civic Government (Scotland) Act 1982,
Application for the Grant of a Market Operators Licence

Applicant: The Briggait

Address: The Briggait, 141 Bridgegate, Glasgow

Ward: 10

Recommendation:

The Committee may grant the licence.

Conditions:

1. A suitable and appropriate system of crowd management will be required to ensure the safe operation of the event and that the maximum capacity figure is not exceeded.
2. The premises should have a current emergency lighting test certificate BS 5266.
3. The premises should have a current electrical installation test certificate BS 7671 or a current Periodic Inspection report for the electrical installation BS 7671
4. The premises should have a current Fire Risk Assessment

Background Information:

It is proposed to hold an indoor market Monday to Sunday 9am to 10pm

The market will consist of 180 stalls with a maximum capacity of 998 persons

Yours faithfully,

Team manager
Building Control & Public Safety

If phoning or visiting please ask for Mr Jim Adams
Direct phone 0141 287 4471, email james.adams@glasgow.gov.uk