



Neighbourhoods Regeneration and
Sustainability
Planning and Building Standards
Exchange House
231 George Street
Glasgow
G1 1RX

MEMORANDUM

Our Ref: JA

Application Ref: PEL00117

Date: 16th April 2025

**CASE 10
(TABLED)**

From: K. Donoghue
Team Leader, Licensing, Planning & Building Standards.

To: G. McNaught
Legal Manager (Licensing), Corporate Services.

Subject: Consultation: Civic Government (Scotland) Act 1982,
Application for the Renewal of a Public Entertainment Licence

Applicant: The Larkfield Centre

Address: 39 Inglefield Street Govanhill Glasgow

Ward:8

Recommendation:

The Committee may grant the licence.

Conditions:

1. The premises should have a current emergency lighting test certificate BS 5266.
2. The premises should have a current electrical installation test certificate BS 7671 or a current Periodic Inspection report for the electrical installation BS 7671.
3. The premises should have a current Fire Risk Assessment

Background Information:

The premise's is a single storey Community Centre located on the east side of Inglefield Street comprising:-

Main Hall	Occupancy Capacity	120 persons standing 100 persons seated
Lesser Hall (divided into 2 smaller rooms)		

Meeting Room/Crèche	Occupancy Capacity	30 persons
Office	Occupancy Capacity	5 persons
Meeting Room	Occupancy Capacity	10 persons

Ladies, Gents and Disabled Toilet, Kitchen, Store etc.

The applicant's maximum capacity within the premises is 165 persons

The opening hours are as follows:-

Mon to Thu 8.30am to 11pm
Fri to Sun 8.30 am to midnight

Yours faithfully,

**Team manager
Building Control & Public Safety**

**If phoning or visiting please ask for Mr Jim Adams
Direct phone 0141 287 4471, email james.adams@glasgow.gov.uk**