



Neighbourhoods Regeneration and
Sustainability
Planning and Building Standards
231 George Street
Glasgow
G1 1RX

MEMORANDUM

CASE 5

Our Ref: JA
Application Ref: PEL01403
Date: 6th June 2025

From: K. Donoghue
Team Manager, Licensing, Planning & Building Standards.

To: G. McNaught
Legal Manager (Licensing), Corporate Services.

Subject: Consultation: Civic Government (Scotland) Act 1982,
Application for the Grant of a Temporary Public Entertainment Licence

Applicant: DF Concerts Limited

Address: Bellahouston Park, 16 Dumbreck Road, Glasgow

Ward: 6

Recommendation:

The Committee may grant the licence.

Conditions:

1. State the total exit width from the event site and provide exit width calculations, making reference to the current Events Safety Guide.
2. Clarify all the expected viewing areas and the resultant crowd density.
3. Provide a specification of the front of stage/ secondary barrier, if appropriate, and show the position of the barrier on the plan, the method of securing the barrier should be stated.
4. Provide risk assessment of how the event areas will operate.
5. Clearly dimensioned plans and calculations of the proposed stages (including details of any towers, roof, lighting truss, foundations, video screens and supports), mixer control platform, and the platform for disabled use require to be submitted.

6. Clearly dimensioned plans of all tented structures will require to be submitted. This should include type, ground fixing or anchor details, design details, wind management requirements and exit and emergency lighting provisions.
7. Section 89 Civic Government (Scotland) Act 1982 approval for any structure 600mm and greater above ground level is required.
8. Details of temporary exit signage and emergency lighting (and positioning) relating to means of escape requires to be provided
9. Wherever possible cable runs and water supply pipes should be contained out-with the public access areas and/or contained within proprietary ducting.
10. An appropriate event management plan and risk assessments must be provided
11. Build and event programmes should be provided at an early stage, in order to facilitate co-ordinated inspections and consultation during the build-up and event.
12. A system of wind/weather management will required for the event and should include all relevant structures.
13. A suitable and appropriate system of crowd management will be required to ensure the safe operation of the event and that the maximum capacity figure is not exceeded.
14. A final inspection will be required prior the release of the licence.

Background Information:

It is proposed to hold an outdoor music event at Bellahouston Park within the area adjacent to Mossspark on the following dates:

Saturday the 27th of June 2026 between 12pm and 11pm (VIP 1pm until 12 Midnight)
Sunday the 28th of June 2026 between 12pm and 11pm (VIP 1pm until 12 Midnight)
Monday the 29th of June 2026 between 4pm and Midnight (VIP 5pm until 12 Midnight)
Tuesday the 30th of June 2026 between 4pm and Midnight (VIP 5pm until 12 Midnight)
Wednesday the 1st of July 2026 between 4pm and Midnight (VIP 5pm until 12 Midnight)
Friday the 3rd of July 2026 between 4pm and Midnight (VIP 5pm until 12 Midnight)
Saturday the 4th of July 2026 between 4pm and Midnight (VIP 5pm until 12 Midnight)

The proposed capacity of the event is 36,000 persons

Yours faithfully,

Team Manager
Building Standards & Public Safety

**If phoning or visiting please ask for Mr Jim Adams
Direct phone 0141 287 4471, email james.adams@glasgow.gov.uk**