



MEMORANDUM

CASE 4

Our Ref: JA
Application Ref: PEL 01402
Date: 7th June 2026

From: K. Donoghue
Team Leader, Licensing, Planning & Building Standards.

To: G. McNaught
Legal Manager (Licensing), Corporate Services.

Subject: Consultation: Civic Government (Scotland) Act 1982,
Application for the Grant of a Temporary Public Entertainment Licence
for an outdoor music festival TRNSMT at Glasgow Green on 19-21/6/26

Applicant: DF Concerts Ltd

Address: Glasgow Green, Greendyke Street, Glasgow

Ward: 9

Recommendation:

The Committee may grant the licence.

Conditions:

1. State the total exit width from the event site and provide exit width calculations, referring to the current Events Safety Guide.
2. Clarify all the expected viewing areas and the resultant crowd density.
3. Provide a specification of the front of stage/ secondary barrier, if appropriate, and show the position of the barrier on the plan, the method of securing the barrier should be stated.
4. Provide risk assessment of how the event areas will operate.
5. Clearly dimensioned plans and calculations of the proposed stages (including details of any towers, roof, lighting truss, foundations, video screens and supports), mixer control platform, and the platform for disabled use require to be submitted.
6. Clearly dimensioned plans of all tented structures will require to be submitted. This should include type, ground fixing or anchor details, design details, wind management requirements and exit and emergency lighting provisions.

7. Section 89 Civic Government (Scotland) Act 1982 approval for any structure 600mm and greater above ground level is required.
8. Details of temporary exit signage and emergency lighting (and positioning) relating to means of escape requires to be provided
9. Wherever possible cable runs and water supply pipes should be contained out-with the public access areas and/or contained within proprietary ducting.
10. An appropriate event management plan and risk assessments must be provided
11. Build and event programmes should be provided at an early stage, in order to facilitate co-ordinated inspections and consultation during the build-up and event.
12. A system of wind/weather management will be required for the event and should include all relevant structures.
13. A suitable and appropriate system of crowd management will be required to ensure the safe operation of the event and that the maximum capacity figure is not exceeded.
14. A final inspection will be required prior the release of the licence.

Background Information:

It is proposed to hold a music event over a period of a weekend in Glasgow Green on the following dates

19th June 2026 between 11am and 1am

20^h June 2026 between 11am and 11pm (12 midnight for VIP)

21st June 2026 between 11am and 11pm (12 midnight for VIP)

The proposed capacity of the event is 50,000 persons

Yours faithfully,

Team manager
Building Control & Public Safety

If phoning or visiting please ask for Mr Jim Adams
Direct phone 0141 287 4471, email james.adams@glasgow.gov.uk