



CASE 9

| | | | |
|-------------------|---|------------------------|------------|
| From: | B Carroll Principal Officer, Housing Intervention & Support Team, NRS | | |
| To: | G McNaught (Legal Manager), CED | | |
| Subject: | Consultation: Housing (Scotland) Act 2006 Application for an Existing House in Multiple Occupation Licence | | |
| Applicant: | Yousaf Saleem | Ward: | 11 |
| Address: | 26 Holyrood Crescent | House Position: | 1-1 |

The following items be satisfactorily completed prior to the grant of the licence and the under noted conditions would be applicable.

Inspection

The premises were inspected on 22 April 2025 in respect of the Council's living standards for houses in multiple occupation. The following matters were directed to the attention of Yousaf Saleem and also to the applicant by email.

1. The complete electrical installation (including portable electrical appliances supplied by the landlord) must be inspected by a competent Electrical Engineer, any defects found must be rectified and an inspection certificate stating its condition must be completed and forwarded to the Executive Director of Neighbourhoods, Regeneration & Sustainability Services, HMO Unit, 231 George Street, Glasgow, G1 1RX.
2. A current Gas Safety Certificate requires to be provided and forwarded to the Executive Director of Neighbourhoods, Regeneration & Sustainability Services, HMO Unit, 231 George Street, Glasgow, G1 1RX. If the application is for the grant of an existing licence then copies of the Gas Safety Certificates for the previous two years also require to be submitted.

Conditions

1. A minimum of one (1) suitable bin with lid for storage of refuse produced by the tenants of the house shall be provided at a suitable location with suitable means of access thereto.
2. The number of residents to be accommodated within the licensed premises shall not exceed three (3) persons.
3. At least once in every five years all electrical systems within the premises shall be examined by a competent person and a certificate provided indicating that all such systems are functioning properly and are safe.
4. At least once in every year all portable appliances within the premises provided for the use of the tenants shall be examined by a competent person and certificates provided indicating that all such appliances are functioning properly and are safe. If the application is for the grant of an existing licence then copies of the portable appliance test certificates for the previous two years also require to be submitted.
5. At least once a year all gas appliances provided for the use of the tenants must be examined by a competent person (i.e. GAS SAFE REGISTERED ENGINEER) and a certificate provided (i.e. LANDLORDS GAS SAFETY CHECK) indicating that they are functioning properly and are safe. Gas certificates must be retained for three years and must be submitted when applying for the renewal of a licence.

Background Information

Description of Property: First floor flat within a traditional tenement building.

Number of Bedrooms: Three (3)

History of Multiple Occupation: First known to be in HMO use on 16 February 2018.

Occupied: Yes, Existing application.

History of Complaints: None

Standard of Management: At the time of inspection there were two outstanding items for completion noted under 'Items for Completion'. These items are relevant in considering the standard of management. Subject to effective steps to address these items for completion, the standard of management may be said to be satisfactory.