



MEMORANDUM

Our Ref: JA
Application Ref: PEL01365
Date: 12th March 2026

CASE 1

From: K. Donoghue
Team Manager, Licensing, Planning & Building Standards.

To: G. McNaught
Legal Manager (Licensing), Corporate Services.

Subject: Consultation: Civic Government (Scotland) Act 1982,
Application for the Grant of a Public Entertainment Licence

Applicant: Kunsupitchya Kulporntavanchai

Address: 2353 Dumbarton Road, Glasgow

Ward: 13

Recommendation:

The Committee may grant the licence.

Conditions:

1. A Building warrant and Completion certificate are required for the alterations to the premises.
2. The premises should have a current emergency lighting test certificate BS 5266.
3. The premises should have a current electrical installation test certificate BS 7671 or a current Periodic Inspection report for the electrical installation BS 7671
4. The premises should have a current Fire Risk Assessment.
5. The premises should have a working fire detection and alarm warning system to BS 5839 Part 1.

Background Information:

A retail unit has been fitted out to form a Massage and Wellness centre located on the southside of Dumbarton Road at the junction with Kelso Street.

The premises consists of 2 treatment rooms with a capacity of 4 persons

Yours faithfully,

Ken Donoghue

Team manager
Building Control & Public Safety

**If phoning or visiting please ask for Mr Jim Adams
Direct phone 0141 287 4471, email james.adams@glasgow.gov.uk**