



MEMORANDUM

CASE 11

Our Ref: HMO/CDI
Application Ref: HMO02428
Date: 16/04/2025

From: B Carroll
Principal Officer, Housing Intervention & Support Team, NRS

To: G McNaught (Legal Manager), CED

Subject: Consultation: Housing (Scotland) Act 2006
Application for an Existing House in Multiple Occupation Licence

Applicant: Sheena Susan Louise Lawson **Ward:** 23

Address: 54 Airlie Street **House Position:** 1-1

Recommendation:

The following items be satisfactorily completed prior to the grant of the licence and the under noted conditions would be applicable.

Items for Completion:

Inspection

The premises were inspected on 15 April 2025 in respect of the Council's living standards for houses in multiple occupation. The following matters were directed to the attention of Mr Barry Kirk, representing DJ Alexander and also to the applicant by email.

1. Within the bathroom both the CH radiator and the cracked window pane should be replaced.

Conditions

1. A minimum of one (1) suitable bin with lid for storage of refuse produced by the tenants of the house shall be provided at a suitable location with suitable means of access thereto.
2. The number of residents to be accommodated within the licensed premises shall not exceed three (3) persons.

3. At least once in every five years all electrical systems within the premises shall be examined by a competent person and a certificate provided indicating that all such systems are functioning properly and are safe.
4. At least once in every year all portable appliances within the premises provided for the use of the tenants shall be examined by a competent person and certificates provided indicating that all such appliances are functioning properly and are safe. If the application is for the grant of an existing licence then copies of the portable appliance test certificates for the previous two years also require to be submitted.
5. At least once a year all gas appliances provided for the use of the tenants must be examined by a competent person (i.e. GAS SAFE REGISTERED ENGINEER) and a certificate provided (i.e. LANDLORDS GAS SAFETY CHECK) indicating that they are functioning properly and are safe. Gas certificates must be retained for three years and must be submitted when applying for the renewal of a licence.

Background Information

Description of Property: First floor flat within a traditional tenement building.

Number of Bedrooms: Three (3)

History of Multiple Occupation: First known to be in HMO use on 10 January 2007.

Occupied: Yes, Existing application.

History of Complaints: None

Standard of Management: At the time of inspection there was one outstanding item for completion noted under 'Items for Completion'. This item is relevant in considering the standard of management. Subject to effective steps to address this item for completion, the standard of management may be said to be satisfactory.