



**Neighbourhoods
Regeneration and
Sustainability
Planning and Building
Standards**
Exchange House
231 George Street
Glasgow
G1 1RX

MEMORANDUM

Our Ref: JA

Application Ref: PEL01336

Date: 10th December 2025

CASE 1

From: K. Donoghue
Team Manager, Licensing, Planning & Building Standards.

To: G. McNaught
Legal Manager (Licensing), Corporate Services.

Subject: Consultation: Civic Government (Scotland) Act 1982,
Application for the Grant of a Public Entertainment
Licence

Applicant: Panisara Goodwin

Address: Suite 3.1, 19 Waterloo
Street, Glasgow **Ward:** 10

Recommendation:

The Committee may grant the licence.

Conditions:

1. A Building Warrant and Completion Certificate will be required for the alterations.
2. The premises should have a current emergency lighting test certificate BS 5266.
3. The premises should have a current electrical installation test certificate BS 7671 or a current Periodic Inspection report for the electrical installation BS 7671
4. The premises should have a current Fire Risk Assessment
5. The premises should have a working fire detection and alarm warning system to BS 5839 Part 1.

Background Information:

It is proposed to fit out an existing office to form a Therapy massage Centre

The capacity of the premise will be 6 persons

Yours faithfully,

Team manager
Building Control & Public Safety

**If phoning or visiting please ask for Mr Jim Adams
Direct phone 0141 287 4471, email james.adams@glasgow.gov.uk**