

Conditions

1. A minimum of one (1) suitable bin with lid for storage of refuse produced by the tenants of the house shall be provided at a suitable location with suitable means of access thereto.
2. The number of residents to be accommodated within the licensed premises shall not exceed five (5) persons.
3. At least once in every five years all electrical systems within the premises shall be examined by a competent person and a certificate provided indicating that all such systems are functioning properly and are safe.
4. At least once in every year all portable appliances within the premises provided for the use of the tenants shall be examined by a competent person and certificates provided indicating that all such appliances are functioning properly and are safe. If the application is for the grant of an existing licence then copies of the portable appliance test certificates for the previous two years also require to be submitted.
5. At least once a year all gas appliances provided for the use of the tenants must be examined by a competent person (i.e. GAS SAFE REGISTERED ENGINEER) and a certificate provided (i.e. LANDLORDS GAS SAFETY CHECK) indicating that they are functioning properly and are safe. Gas certificates must be retained for three years and must be submitted when applying for the renewal of a licence.

Background Information

Description of Property: Third floor and attic flat within a three storey tenement with a commercial unit on the ground floor.

Number of Bedrooms: Five (5)

History of Multiple Occupation: First known to be a HMO on 13th June 2018

Occupied: Yes, existing application.

History of Complaints: None

Standard of Management: At time of inspection there were three outstanding items for completion brought to the attention of the owner under "Items for Completion". These matters are relevant in considering the standard of management. Assuming these are effectively addressed the standard of management may be said to be satisfactory.

Other Information: None